



**Department of Public Works
Milwaukee Water Works**

July 5, 2011
Official Notice No. 11-127-1
Addendum No. 3

Jeffrey J. Mantes
Commissioner of Public Works

Preston D. Cole
Director of Operations

Carrie M. Lewis
Superintendent of Water Works

To Whom It May Concern:

Recently you received plans and bid documents for a Water Main Relay in the City of Milwaukee, Official Notice No. 11-127-1.

The construction plan has been revised following the pre-bid meeting held on Tuesday, June 28, 2011. Revisions were made to the connections on both ends of the project to facilitate pressure testing. The 42" x 36" reducing couplings have been eliminated. The new design utilizes a 42" transition coupling, 42" x 36" reducer, 36" HDPE-MJ adapter, and 36" test caps. The reducers (2) and test caps (2) will be furnished by the City. The revised plan is available electronically via <http://www.mpw.net/bids/docs/127-2011/>. If necessary, revised plans can also be picked up in room 506, Frank P. Zeidler Municipal Building, 841 North Broadway, Milwaukee, Wisconsin 53202.

The bid items have been revised to reflect the design change. Bidders should use the new bid sheets, labeled "Addendum No. 3", dated June 29, 2011, when submitting the bid.

The bid date listed in the contract documents, Friday, July 8, 2011, has been changed. The new bid date will be Friday, July 15, 2011.

Each bidder shall acknowledge receipt of this addendum in the bid documents.

If you have any questions regarding this, please contact Mr. Mark Scheller at 414-286-2427.

Your interest in this project is greatly appreciated.

Very truly yours,

Dinah G. Gant, P.E.
Chief Design Engineer
Milwaukee Water Works

DGG